



Reg. No. 041/P-007

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



Certificate of constancy of performance

1396 – CPR – 0013

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

NATURAL SMOKE AND HEAT EXHAUST VENTILATOR, type FSP

used as a dual purpose ventilator, having the performances and used in conditions given by initial type testing report No.: C1396/07/0010/5003/SC, issued by FIRES s.r.o., Batizovce, Slovakia, on 21. 05. 2007,

produced by

FAKRO Sp. z o.o.
ul. Węgierska 144 A, 33-300 Nowy Sącz, Poland

and produced in the manufacturing plant

FAKRO Sp. z o.o.
ul. Węgierska 144 A, 33-300 Nowy Sącz, Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 12101-2: 2003

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 21. 05. 2007 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Batizovce, 29. 05. 2014



Ing. Mária Gašperová
Ing. Mária Gašperová
Head of Product Certification Body

064203 FIRES 136a/C-12/12/2013-E